

Daily Environmental Report

STP - Embassy Golflinks-Sunriver, Embassy Tech Park Bangalore
Karnataka
(2025/12/16 to 2025/12/16)

Water Quality

| Parameter | Avg Value | Min Value | Max Value | Acceptable Max Limit |
|-----------|-----------|-----------|-----------|----------------------|
| ph | 7.43 | 7.00 | 7.46 | N/A |
| TURB | 0.01 | 0.01 | 0.01 | N/A |
| Temp | 28.37 | 27.32 | 29.26 | N/A |
| BOD | 7.58 | 3.87 | 9.56 | N/A |
| COD | 36.44 | 28.25 | 39.63 | N/A |
| TSS | 13.11 | 9.79 | 17.15 | N/A |

Water Quantity

| Name | Initial Reading | Final Meter Reading | Total |
|------------|-----------------|---------------------|-------|
| STP inlet | 67347.80 | 67409.50 | 61.70 |
| STP outlet | 64165.80 | 64206.20 | 40.40 |

Energy Report

| Stack Name | Initial Reading | Last Reading | Total kWh |
|---------------------------|-----------------|--------------|-----------|
| No energy data available. | | | |