

Daily Environmental Report

STP - Embassy Golflinks-Sunriver, Embassy Tech Park Bangalore
Karnataka
(2025/12/11 to 2025/12/11)

Water Quality

| Parameter | Avg Value | Min Value | Max Value | Acceptable Max Limit |
|-----------|-----------|-----------|-----------|----------------------|
| ph | 7.41 | 7.00 | 7.46 | N/A |
| TURB | 0.01 | 0.01 | 0.01 | N/A |
| Temp | 28.24 | 27.32 | 29.26 | N/A |
| BOD | 7.15 | 3.87 | 9.56 | 30.00 |
| COD | 36.82 | 28.25 | 45.68 | N/A |
| TSS | 13.32 | 9.79 | 17.52 | 100.00 |

Water Quantity

| Name | Initial Reading | Final Meter Reading | Total |
|------------|-----------------|---------------------|-------|
| STP inlet | 67107.40 | 67185.80 | 78.40 |
| STP outlet | 63997.90 | 64052.00 | 54.10 |

Energy Report

| Stack Name | Initial Reading | Last Reading | Total kWh |
|---------------------------|-----------------|--------------|-----------|
| No energy data available. | | | |