

# Daily Environmental Report

STP - Embassy Golflinks-Sunriver, Embassy Tech Park Bangalore  
Karnataka  
(2025/12/09 to 2025/12/09)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.42	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.08	27.32	29.26	N/A
BOD	6.20	3.87	9.56	30.00
COD	38.46	28.25	44.12	N/A
TSS	11.76	9.79	14.18	100.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	66959.80	67032.50	72.70
STP outlet	63895.70	63945.70	50.00

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			