

Report for Hilton Manyata

Date:21/02/2025

Quality Report

Parameter	Avg Value	Min Limit	Max Limit	Exceedence
ph	6.70	-	-	-
Temp	29.81	-	-	-
BOD	13.41	11.5	14.8	10
COD	23.31	20.9	25.05	20
TSS	11.42	9.2	12.3	10

Energy Report

Station	Initial Reading	Final Reading	Consumption kWh
STP-energy	498823.13	499274.53	451.41

Water Quality Report

Station	Initial Reading	Final Reading	Consumption m3
ETP outlet	0.00	0.00	0.00
STP inlet	1467.10	55.80	1411.30
STP acf outlet	1737.40	1837.00	99.60
STP uf outlet	3430.40	3586.70	156.30
STP softener outlet	2444.90	2540.70	95.80
STP garden outlet 1	5869.60	0.00	5869.60
STP garden outlet 2	0.00	0.00	0.00