

Report for Hilton Manyata

Date:29/03/2025

Quality Report

Parameter	Avg Value	Min Limit	Max Limit	Exceedence
ph	7.16	6.5	7.8	-
Temp	29.15	29.8	29.9	-
BOD	14.93	14.93	14.93	-
COD	22.00	22	22	-
TSS	12.31	11.97	12.58	-

Energy Report

Station	Initial Reading	Final Reading	Consumption kWh
STP-energy	525015.13	525689.19	674.06

Water Quality Report

Station	Initial Reading	Final Reading	Consumption m3
ETP outlet	0.00	0.00	0.00
STP inlet	3844.60	3940.90	96.30
STP acf outlet	4950.70	5083.40	132.70
STP uf outlet	1536.50	1711.90	175.40
STP softener outlet	5509.60	5585.00	75.40
STP garden outlet 1	1401.30	1401.30	0.00
STP garden outlet 2	33.40	57.60	24.20