

Daily Environmental Report

STP - Embassy Golflinks - MLCP, 6, Embassy Golf Links Business Park, Domlur, Bengaluru, Karnataka 560071
(2025/12/28 to 2025/12/28)

Water Quality

| Parameter | Avg Value | Min Value | Max Value | Acceptable Max Limit |
|-----------|-----------|-----------|-----------|----------------------|
| ph | 7.38 | 7.00 | 7.46 | N/A |
| TURB | 0.01 | 0.01 | 0.01 | N/A |
| Temp | 28.16 | 27.32 | 29.26 | N/A |
| BOD | 5.34 | 3.87 | 8.13 | N/A |
| COD | 36.51 | 28.25 | 40.61 | N/A |
| TSS | 11.65 | 9.79 | 14.37 | N/A |

Water Quantity

| Name | Initial Reading | Final Meter Reading | Total |
|------------|-----------------|---------------------|-------|
| STP inlet | 144476.70 | 144489.10 | 12.40 |
| STP outlet | 208026.00 | 208048.50 | 22.50 |

Energy Report

| Stack Name | Initial Reading | Last Reading | Total kWh |
|---------------------------|-----------------|--------------|-----------|
| No energy data available. | | | |