

Report for Hilton Manyata

Date:16/04/2025

Quality Report

Parameter	Avg Value	Min Limit	Max Limit	Exceedence
ph	7.03	6.6	7.7	-
Temp	29.28	27	30	-
BOD	8.45	7.465	9.564	-
COD	17.58	15.434	19.5378	-
TSS	11.61	8.5693	13.6652	-

Energy Report

Station	Initial Reading	Final Reading	Consumption kWh
STP-energy	538093.38	538772.63	679.25

Water Quality Report

Station	Initial Reading	Final Reading	Consumption m3
ETP outlet	0.00	0.00	0.00
STP inlet	5872.40	5969.90	97.50
STP acf outlet	197.20	323.50	126.30
STP uf outlet	4116.10	4269.10	153.00
STP softener outlet	734.30	892.50	158.20
STP garden outlet 1	1481.70	1486.60	4.90
STP garden outlet 2	82.80	85.70	2.90