

# Daily Environmental Report

STP - Embassy Golflinks - Hilton, off Intermediate Ring Road,  
Embassy Golf Links Business Park, Challaghatta, Bengaluru,  
Karnataka 560071  
(2025/11/14 to 2025/11/14)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.49	7.39	7.50	N/A
TURB	1.01	1.01	1.01	N/A
Temp	30.16	29.80	30.23	N/A
BOD	9.35	9.24	9.39	10.00
COD	45.38	44.97	45.52	50.00
TSS	9.22	9.11	9.26	10.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	57984.90	58053.80	68.90
STP outlet	15736.44	15859.10	122.66

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			