

# Report for Hilton Manyata

Date:22/04/2025

## Quality Report

Parameter	Avg Value	Min Limit	Max Limit	Exceedence
ph	7.06	6.6	7.7	-
Temp	29.15	27	30	-
BOD	8.37	7.465	9.564	-
COD	20.65	17.0933	24.0278	-
TSS	12.35	9.8665	14.2212	-

## Energy Report

Station	Initial Reading	Final Reading	Consumption kWh
STP-energy	542481.63	543186.00	704.38

## Water Quality Report

Station	Initial Reading	Final Reading	Consumption m3
ETP outlet	0.00	0.00	0.00
STP inlet	6479.10	6534.40	55.30
STP acf outlet	803.80	875.40	71.60
STP uf outlet	4939.70	5016.30	76.60
STP softener outlet	1364.10	1438.50	74.40
STP garden outlet 1	1511.40	1511.40	0.00
STP garden outlet 2	171.50	189.90	18.40