

Report for Embassy Golflinks - Pine Valley

Date:24/06/2025

Quality Report

Parameter	Avg Value	Min Limit	Max Limit	Exceedence
ph	7.68	7.61	7.8	-
TURB	4.01	4.01	4.01	-
Temp	28.06	27.84	28.13	-
BOD	9.42	8.52	11.1	-
COD	27.96	26.56	30.54	-
TSS	19.86	19.34	20.83	-
cumulatingFlow	0.00	-	-	-
flowRate	0.00	-	-	-
energy	0.00	-	-	-
voltage	0.00	-	-	-
current	0.00	-	-	-
power	0.00	-	-	-
weight	0.00	-	-	-

No energy report available.

Water Quality Report

Station	Initial Reading	Final Reading	Consumption m3
STP outlet	17506.10	17662.80	156.70
STP inlet	122243.30	122391.00	147.70