

# Daily Environmental Report

STP - Embassy Golflinks - MLCP, 6, Embassy Golf Links Business Park, Domlur, Bengaluru, Karnataka 560071  
(2025/10/27 to 2025/10/27)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.41	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.01	27.32	29.26	N/A
BOD	6.16	3.87	9.56	30.00
COD	36.53	28.25	40.41	N/A
TSS	12.06	9.79	16.77	100.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	137597.60	137770.10	172.50
STP outlet	199531.70	199629.90	98.20

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			