

# Report for Embassy Golflinks - Pine Valley

Date:28/06/2025

## Quality Report

| Parameter      | Avg Value | Min Limit | Max Limit | Exceedence |
|----------------|-----------|-----------|-----------|------------|
| ph             | 7.62      | 7.55      | 7.83      | -          |
| TURB           | 1.01      | 1.01      | 4.01      | -          |
| Temp           | 28.13     | 28.04     | 28.18     | -          |
| BOD            | 7.30      | 6.99      | 7.81      | -          |
| COD            | 29.98     | 24.27     | 30        | -          |
| TSS            | 4.00      | 4         | 18.48     | -          |
| cumulatingFlow | 0.00      | -         | -         | -          |
| flowRate       | 0.00      | -         | -         | -          |
| energy         | 0.00      | -         | -         | -          |
| voltage        | 0.00      | -         | -         | -          |
| current        | 0.00      | -         | -         | -          |
| power          | 0.00      | -         | -         | -          |
| weight         | 0.00      | -         | -         | -          |

No energy report available.

## Water Quality Report

| Station    | Initial Reading | Final Reading | Consumption m3 |
|------------|-----------------|---------------|----------------|
| STP outlet | 18240.00        | 18294.20      | 54.20          |
| STP inlet  | 122930.00       | 122975.70     | 45.70          |