

# Daily Environmental Report

STP - Embassy Golflinks - MLCP, 6, Embassy Golf Links Business Park, Domlur, Bengaluru, Karnataka 560071  
(2025/11/11 to 2025/11/11)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.40	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.20	27.32	29.26	N/A
BOD	5.52	3.87	8.80	30.00
COD	36.19	28.25	38.56	N/A
TSS	12.78	9.79	15.94	100.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	140302.20	140387.10	84.90
STP outlet	201784.20	201850.80	66.60

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			