

Report for Hilton Manyata

Date:30/04/2025

Quality Report

Parameter	Avg Value	Min Limit	Max Limit	Exceedence
ph	7.04	6.6	7.7	-
Temp	28.93	27	30	-
BOD	8.29	7.465	9.564	-
COD	19.21	16.6096	21.978	-
TSS	10.68	8.567	13.9432	-

Energy Report

Station	Initial Reading	Final Reading	Consumption kWh
STP-energy	548915.63	549656.56	740.94

Water Quality Report

Station	Initial Reading	Final Reading	Consumption m3
ETP outlet	0.00	0.00	0.00
STP inlet	801.90	908.40	106.50
STP acf outlet	1597.00	1693.60	96.60
STP uf outlet	6094.70	6235.10	140.40
STP softener outlet	2156.10	2247.70	91.60
STP garden outlet 1	1552.60	1552.60	0.00
STP garden outlet 2	296.00	317.50	21.50