

Report for Hilton Manyata

Date:20/03/2025

Quality Report

Parameter	Avg Value	Min Limit	Max Limit	Exceedence
ph	7.17	6.5	7.8	-
Temp	22.31	29.66	29.75	-
BOD	13.94	13.77	14.05	-
COD	28.86	28.41	29.13	-
TSS	10.28	9.98	10.71	-

Energy Report

Station	Initial Reading	Final Reading	Consumption kWh
STP-energy	518464.69	519202.31	737.63

Water Quality Report

Station	Initial Reading	Final Reading	Consumption m3
ETP outlet	0.00	0.00	0.00
STP inlet	2858.10	2966.50	108.40
STP acf outlet	4018.70	4138.20	119.50
STP uf outlet	130.00	300.40	170.40
STP softener outlet	4548.80	4696.90	148.10
STP garden outlet 1	1353.80	1353.80	0.00
STP garden outlet 2	0.00	0.00	0.00