

# Daily Environmental Report

STP - Embassy Golflinks - MLCP, 6, Embassy Golf Links Business Park, Domlur, Bengaluru, Karnataka 560071  
(2026/01/16 to 2026/01/16)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.39	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.40	27.32	29.26	N/A
BOD	6.51	3.87	8.71	N/A
COD	38.68	28.25	45.49	N/A
TSS	11.31	9.79	14.37	N/A

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	146106.70	146205.60	98.90
STP outlet	210092.90	210203.50	110.60

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			