

# Daily Environmental Report

STP - Embassy Golflinks-Sunriver, Embassy Tech Park Bangalore  
Karnataka  
(2026/01/21 to 2026/01/21)

## Water Quality

| Parameter | Avg Value | Min Value | Max Value | Acceptable Max Limit |
|-----------|-----------|-----------|-----------|----------------------|
| ph        | 7.41      | 7.00      | 7.46      | N/A                  |
| TURB      | 0.01      | 0.01      | 0.01      | N/A                  |
| Temp      | 28.16     | 27.32     | 29.26     | N/A                  |
| BOD       | 4.18      | 3.87      | 9.56      | N/A                  |
| COD       | 39.99     | 28.25     | 43.73     | N/A                  |
| TSS       | 11.29     | 9.79      | 15.29     | N/A                  |

## Water Quantity

| Name       | Initial Reading | Final Meter Reading | Total |
|------------|-----------------|---------------------|-------|
| STP inlet  | 0.00            | 0.00                | 0.00  |
| STP outlet | 0.00            | 0.00                | 0.00  |

## Energy Report

| Stack Name                | Initial Reading | Last Reading | Total kWh |
|---------------------------|-----------------|--------------|-----------|
| No energy data available. |                 |              |           |