

Report for HOCL

Date:20/03/2025

Quality Report

| Parameter | Avg Value | Min Limit | Max Limit | Exceedence |
|-----------|-----------|-----------|-----------|------------|
| ph | 7.81 | 7 | 9 | - |
| BOD | 6.23 | 3.53 | 10.64 | - |
| COD | 43.95 | 29.9 | 67.48 | - |
| TSS | 17.34 | 16 | 19.5 | - |
| Flow | 11.93 | 0 | 67.3 | - |

No energy report available.

No water quality report available.