

# Daily Environmental Report

STP - Embassy Golflinks-Sunriver, Embassy Tech Park Bangalore  
Karnataka  
(2026/01/14 to 2026/01/14)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.40	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.24	27.32	29.26	N/A
BOD	6.97	3.87	9.56	N/A
COD	36.68	28.25	40.80	N/A
TSS	12.18	9.79	15.01	N/A

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	68694.50	68759.90	65.40
STP outlet	65112.70	65159.60	46.90

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			