

# Daily Environmental Report

STP - Embassy Golflinks - MLCP, 6, Embassy Golf Links Business Park, Domlur, Bengaluru, Karnataka 560071  
(2025/12/21 to 2025/12/21)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.42	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.31	27.32	29.26	N/A
BOD	6.91	3.87	9.56	N/A
COD	36.37	28.25	39.73	N/A
TSS	12.31	9.79	15.29	N/A

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	143958.10	143967.20	9.10
STP outlet	207358.30	207390.80	32.50

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			