

# Daily Environmental Report

STP - Embassy Golflinks - MLCP, 6, Embassy Golf Links Business Park, Domlur, Bengaluru, Karnataka 560071  
(2025/12/17 to 2025/12/17)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.39	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.19	27.32	29.26	N/A
BOD	6.71	3.87	9.56	N/A
COD	36.08	28.25	39.92	N/A
TSS	11.64	9.79	16.22	N/A

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	143517.80	143647.40	129.60
STP outlet	206767.60	206937.90	170.30

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			