

Report for Hilton Manyata

Date:17/03/2025

Quality Report

Parameter	Avg Value	Min Limit	Max Limit	Exceedence
ph	7.15	6.5	7.8	-
Temp	24.83	29.45	29.48	-
BOD	12.85	12.67	13.04	-
COD	26.13	25.7	26.65	-
TSS	9.40	9.24	9.54	-

Energy Report

Station	Initial Reading	Final Reading	Consumption kWh
STP-energy	516410.69	517024.31	613.63

Water Quality Report

Station	Initial Reading	Final Reading	Consumption m3
ETP outlet	0.00	0.00	0.00
STP inlet	2517.60	2619.20	101.60
STP acf outlet	3747.60	3843.50	95.90
STP uf outlet	6233.10	6342.70	109.60
STP softener outlet	4213.70	4322.50	108.80
STP garden outlet 1	1342.00	1353.80	11.80
STP garden outlet 2	0.00	0.00	0.00