

# Daily Environmental Report

**STP - Embassy Golflinks - MLCP, 6, Embassy Golf Links Business  
Park, Domlur, Bengaluru, Karnataka 560071  
(2025/12/23 to 2025/12/23)**

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.40	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.20	27.32	29.26	N/A
BOD	6.85	3.87	9.56	N/A
COD	36.84	28.25	40.02	N/A
TSS	12.57	9.79	15.01	N/A

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	144065.20	144190.20	125.00
STP outlet	207482.00	207637.40	155.40

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			