

# Daily Environmental Report

STP - Embassy Golflinks - MLCP, 6, Embassy Golf Links Business Park, Domlur, Bengaluru, Karnataka 560071  
(2026/01/06 to 2026/01/06)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.36	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	27.91	27.32	29.26	N/A
BOD	6.34	3.87	9.56	N/A
COD	36.65	28.25	41.39	N/A
TSS	11.88	9.79	18.04	N/A

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	145068.50	145171.40	102.90
STP outlet	208770.10	208913.70	143.60

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			