

# Report for Hilton Manyata

Date:09/05/2025

## Quality Report

Parameter	Avg Value	Min Limit	Max Limit	Exceedence
ph	7.02	6.6	7.7	-
Temp	29.53	29	30	-
BOD	8.62	7.87	9.564	-
COD	16.92	15.434	18.4599	-
TSS	11.40	8.567	14.3115	-

## Energy Report

Station	Initial Reading	Final Reading	Consumption kWh
STP-energy	551649.94	551649.94	0.00

## Water Quality Report

Station	Initial Reading	Final Reading	Consumption m3
ETP outlet	0.00	0.00	0.00
STP inlet	1775.60	1893.20	117.60
STP acf outlet	2469.00	2527.30	58.30
STP uf outlet	888.80	1040.10	151.30
STP softener outlet	3234.20	3427.90	193.70
STP garden outlet 1	1552.60	1558.50	5.90
STP garden outlet 2	406.80	414.70	7.90