

# Daily Environmental Report

STP - Embassy Golflinks - Torrey Pines, Embassy Golf Links  
Business Park, Challaghatta, Bengaluru, Karnataka 560071  
(2025/10/28 to 2025/10/28)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.42	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.33	27.32	29.26	N/A
BOD	6.91	3.87	9.56	30.00
COD	36.40	28.25	41.10	N/A
TSS	11.40	9.79	14.00	100.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	13283.00	13309.80	26.80
STP outlet	331973.50	332633.70	660.20

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			