

# Daily Environmental Report

**STP - Embassy Golflinks - Pine Valley, EMBASSY GOLF LINKS  
BUSINESS PARK-1, Inner Rd, Embassy Golf Links Business Park,  
Challaghatta, Bengaluru, Karnataka 560071  
(2025/12/11 to 2025/12/11)**

## Water Quality

| Parameter | Avg Value | Min Value | Max Value | Acceptable Max Limit |
|-----------|-----------|-----------|-----------|----------------------|
| ph        | 7.42      | 7.00      | 7.46      | N/A                  |
| TURB      | 0.01      | 0.01      | 0.01      | N/A                  |
| Temp      | 28.45     | 27.32     | 29.26     | N/A                  |
| BOD       | 7.45      | 3.87      | 9.56      | 30.00                |
| COD       | 37.50     | 28.25     | 43.73     | N/A                  |
| TSS       | 12.03     | 9.79      | 15.66     | 100.00               |

## Water Quantity

| Name       | Initial Reading | Final Meter Reading | Total |
|------------|-----------------|---------------------|-------|
| STP inlet  | 157005.10       | 157085.30           | 80.20 |
| STP outlet | 147072.50       | 147072.50           | 0.00  |

## Energy Report

| Stack Name                | Initial Reading | Last Reading | Total kWh |
|---------------------------|-----------------|--------------|-----------|
| No energy data available. |                 |              |           |