

# Daily Environmental Report

**STP - Embassy Golflinks - Pine Valley, EMBASSY GOLF LINKS  
BUSINESS PARK-1, Inner Rd, Embassy Golf Links Business Park,  
Challaghatta, Bengaluru, Karnataka 560071  
(2025/11/14 to 2025/11/14)**

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.40	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.20	27.32	29.26	N/A
BOD	6.68	3.87	9.56	30.00
COD	36.52	28.25	42.17	N/A
TSS	11.42	9.79	14.64	100.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	154717.90	154809.50	91.60
STP outlet	147072.50	147072.50	0.00

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			