

Report for Embassy Golflinks - Cinnabar Hills

Date:28/06/2025

Quality Report

Parameter	Avg Value	Min Limit	Max Limit	Exceedence
ph	8.83	7.37	12.9	-
TURB	2.01	1.01	5.01	-
Temp	27.04	26.94	27.07	-
BOD	6.88	4.85	8	-
COD	24.09	20.93	25	-
TSS	10.03	7.35	17.95	-
cumulatingFlow	0.00	-	-	-
flowRate	0.00	-	-	-
energy	0.00	-	-	-
voltage	0.00	-	-	-
current	0.00	-	-	-
power	0.00	-	-	-
weight	0.00	-	-	-

No energy report available.

Water Quality Report

Station	Initial Reading	Final Reading	Consumption m3
STP outlet	114688.80	114741.30	52.50
STP inlet	119199.90	119238.30	38.40