

# Report for Embassy Golflinks-Sunriver

Date:10/10/2025

## Quality Report

Parameter	Avg Value	Min Limit	Max Limit	Exceedence
ph	7.42	7	7.46	-
TURB	0.01	0.01	0.01	-
Temp	28.14	27.32	29.26	-
BOD	5.35	3.87	9.56	-
COD	36.11	28.25	38.36	-
TSS	11.30	9.79	13.72	-
cumulatingFlow	0.00	-	-	-
flowRate	0.00	-	-	-
energy	0.00	-	-	-
voltage	0.00	-	-	-
current	0.00	-	-	-
power	0.00	-	-	-
weight	0.00	-	-	-

No energy report available.

## Water Quality Report

Station	Initial Reading	Final Reading	Consumption m3
STP outlet	61464.30	61520.70	56.40
STP inlet	63547.30	63620.90	73.60