

# Daily Environmental Report

STP - Embassy Golflinks - MLCP, 6, Embassy Golf Links Business Park, Domlur, Bengaluru, Karnataka 560071  
(2025/12/09 to 2025/12/09)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.40	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	27.89	27.32	29.26	N/A
BOD	6.75	3.87	9.56	30.00
COD	36.36	28.25	40.31	N/A
TSS	12.76	9.79	16.87	100.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	143056.00	143099.80	43.80
STP outlet	205642.40	205816.10	173.70

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			