




Project: AutographPC example for gassy wells
Customer: Sertecpet
Well: HPS
Engineer: Carlos Villacres
Country: EC
State:
County:
Well API#:
Reservoir Name:

Pump: 26-675HC27000Standard
ThChmbr: HDTC
Motor: Teco TEFC 800 HP 460 V/ 867 A (60 Hz)
Controller: VSD 8700-VT 748kVA 480V/ 900A
Sensor: none

Comments:

26-675HC27000Standard

Power (HP)





Project: AutographPC example for gassy wells
Customer: Sertecpet
Well: HPS
Engineer: Carlos Villacres
Country: EC
State:
County:
Well API#:
Reservoir Name:

Pump: 26-675HC27000Standard
ThChmbr: HDTC
Motor: Teco TEFC 800 HP 460 V/ 867 A (60 Hz)
Controller: VSD 8700-VT 748kVA 480V/ 900A
Sensor: none

Comments:

Operating Parameters / Selection:

Design Point:

Desired flow (total) 32000 BPD
Frequency 61.0 Hz
Boost Pressure 600.0 psi

Pump Selection:

	<u>Intake</u>	<u>Discharge</u>
Pressure	120.0 psi	720.0 psi
Flowrate	32000 BPD	32000 BPD
Specific Gravity	0.92 rel-H2O	0.92 rel-H2O
Viscosity	50.0Cp	50.0Cp

Pump Selected:

26-675HC27000Standard
Pump eff = 55.38%
Pshaft RPM = 3644
Shft HP @ 61.0 Hz = 590.4
Shaft load =(Std 71%) / (HS 45%)
Required Motor HP at 60.0 Hz = 586.9

Thrust Chamber Selection:

Type HDTC
No sand present
Pump uses fixed-type stages
Thrust Load 25.6 %
ShaftHPcap 1245 HP

Pressure Data:

Max Working Pressure 1044 psi
Max Allowable Working Pressure 1700 psi

Surface Motor Selection

Motor Selected	=Teco TEFC 800 HP 460 V 867 A	Max Elevation	= 3300ft
Terminal Voltage	=467.4 V	Max Amb Temp	=104.0°F
Motor Current	=645.3 A	Power Type	=UNFILT
Load acc to N.P.	=73.4 %	Frame	=6808A

No comments

Controller Selection:

Surface KW	469.7kW	Voltage Input	480.0V
Input kVA	546.8kVA	Max Well Head Volts	467.4V
System kW	479.3kW	Target Frequency	61.0Hz (7.87V/Hz)
Max Ctrl Current	645.3A	Step-up Trafo	1.0 ratio
Power Cost/kWH	0.05\$/kWH	Selected:	VSD 8700-VT 748kVA/ 480V/ 900A
Total Power Cost	= \$17253/month		

No comments