

Section 1. Registration Information

Source Identification

Facility Name:	Home Juice Company
Parent Company #1 Name:	National Beverage Corp
Submission Type:	First Time
Receipt Date:	April 2000
Status:	Deregistered
Deregistration Effective Date:	September 2000

Facility Identification

Facility ID:	1000 0016 9015
--------------	----------------

Dun and Bradstreet Numbers (DUNS)

Facility DUNS:	5128461
----------------	---------

Facility Location Address

Street 1:	2000 N. 15th Avenue
Street 2:	N/A
City:	Melrose Park
State:	IL
ZIP:	60160
ZIP4:	1473
County:	Cook

Facility Latitude and Longitude

Latitude (decimal):	41.912
Longitude (decimal):	-87.852639

Local Emergency Planning Committee and Regulations

LEPC:	Cook County LEPC
OSHA PSM:	Yes
EPCRA 302:	Yes
CAA Title V:	N/A

Process Chemicals

Program Level:	Program Level 3 process
Chemical Name:	Ammonia (anhydrous)
CAS Number:	7664-41-7
Flammable/Toxic:	Toxic

Process NAICS

NAICS Code:	311421
NAICS Description:	Fruit and Vegetable Canning

Section 6. Accident History

Accident History ID: Accident 1

Date of Accident:	July 1999
Time Accident Began (HH:MM):	20:49
NAICS Code of Process Involved:	311421
NAICS Description:	Fruit and Vegetable Canning
Release Duration:	001 Hours 26 Minutes

Release Event

Gas Release:	Yes
Liquid Spill/Evaporation:	N/A
Fire:	N/A
Explosion:	N/A
Uncontrolled/Runaway Reaction:	N/A

Release Source

Storage Vessel:	Yes
Piping:	N/A
Process Vessel:	N/A
Transfer Hose:	N/A
Valve:	N/A
Pump:	N/A
Joint:	N/A
Other Release Source:	N/A

Weather Conditions at the Time of Event

Wind Speed:	N/A
Units:	Meters/second
Direction:	N/A
Temperature:	N/A
Atmospheric Stability Class:	N/A
Precipitation Present:	N/A
Unknown Weather Conditions:	Yes

On-Site Impacts

Employee or Contractor Deaths:	0
Public Responder Deaths:	0
Public Deaths:	0
Employee or Contractor Injuries:	0
Public Responder Injuries:	0
Public Injuries:	0
On-Site Property Damage (\$):	0

Known Off-Site Impacts

Deaths:	0
Hospitalizations:	0
Public Deaths:	0
Other Medical Treatments:	0
Evacuated:	35
Sheltered-in-Place:	0
Off-Site Property Damage (\$):	0

Environmental Damage

Fish or Animal Kills:	N/A
Tree, Lawn, Shrub, or Crop Damage:	N/A
Water Contamination:	N/A
Soil Contamination:	N/A
Other Environmental Damage:	No environmental damage of any kind

Initiating Event

Initiating Event:	Equipment Failure
-------------------	-------------------

Contributing Factors

Equipment Failure:	Yes
Human Error:	N/A
Improper Procedures:	N/A
Overpressurization:	Yes
Upset Condition:	N/A
By-Pass Condition:	N/A
Maintenance Activity/Inactivity:	N/A
Process Design Failure:	Yes
Unsuitable Equipment:	N/A
Unusual Weather Condition:	N/A
Management Error:	N/A
Other Contributing Factor:	Ammonia trapped and with pressure exceeding relief valve design value.

Off-Site Responders Notified

Off-Site Responders Notified:	Notified and Responded
-------------------------------	------------------------

Changes Introduced as a Result of the Accident

Improved or Upgraded Equipment:	Yes
Revised Maintenance:	Yes
Revised Training:	Yes
Revised Operating Procedures:	Yes
New Process Controls:	N/A
New Mitigation Systems:	N/A
Revised Emergency Response Plan:	Yes
Changed Process:	N/A
Reduced Inventory:	N/A
None:	N/A
Other Changes Introduced:	Installed bypass back pressure regulator.

Chemicals in Accident History

Quantity Released (lbs):	280
Percent Weight:	99.9
Chemical Name:	Ammonia (anhydrous)
CAS Number:	7664-41-7
Flammable/Toxic:	Toxic

Accident History ID: Accident 2

Date of Accident:	May 1999
Time Accident Began (HH:MM):	17:45
NAICS Code of Process Involved:	311421
NAICS Description:	Fruit and Vegetable Canning
Release Duration:	000 Hours 30 Minutes

Release Event

Gas Release:	Yes
Liquid Spill/Evaporation:	N/A
Fire:	N/A
Explosion:	N/A
Uncontrolled/Runaway Reaction:	N/A

Release Source

Storage Vessel:	N/A
Piping:	Yes
Process Vessel:	N/A
Transfer Hose:	N/A
Valve:	N/A
Pump:	N/A
Joint:	Yes
Other Release Source:	Flange loosened

Weather Conditions at the Time of Event

Wind Speed:	N/A
Units:	Meters/second
Direction:	N/A
Temperature:	N/A
Atmospheric Stability Class:	N/A
Precipitation Present:	N/A
Unknown Weather Conditions:	Yes

On-Site Impacts

Employee or Contractor Deaths:	0
Public Responder Deaths:	0
Public Deaths:	0
Employee or Contractor Injuries:	0
Public Responder Injuries:	0
Public Injuries:	0
On-Site Property Damage (\$):	0

Known Off-Site Impacts

Deaths:	0
Hospitalizations:	0
Public Deaths:	0
Other Medical Treatments:	5
Evacuated:	0
Sheltered-in-Place:	0
Off-Site Property Damage (\$):	0

Environmental Damage

Fish or Animal Kills:	N/A
Tree, Lawn, Shrub, or Crop Damage:	N/A
Water Contamination:	N/A
Soil Contamination:	N/A
Other Environmental Damage:	No environmental damage of any kind

Initiating Event

Initiating Event:	Equipment Failure
-------------------	-------------------

Contributing Factors

Equipment Failure:	Yes
Human Error:	N/A
Improper Procedures:	N/A
Overpressurization:	Yes
Upset Condition:	N/A
By-Pass Condition:	N/A
Maintenance Activity/Inactivity:	Yes
Process Design Failure:	N/A
Unsuitable Equipment:	N/A
Unusual Weather Condition:	N/A
Management Error:	N/A
Other Contributing Factor:	N/A

Off-Site Responders Notified

Off-Site Responders Notified:	Notified and Responded
-------------------------------	------------------------

Changes Introduced as a Result of the Accident

Improved or Upgraded Equipment:	Yes
Revised Maintenance:	Yes
Revised Training:	Yes
Revised Operating Procedures:	Yes
New Process Controls:	N/A
New Mitigation Systems:	N/A
Revised Emergency Response Plan:	Yes
Changed Process:	N/A
Reduced Inventory:	N/A
None:	N/A
Other Changes Introduced:	Replaced flange with welded straight pipe

Chemicals in Accident History

Quantity Released (lbs):	3
Percent Weight:	99.9
Chemical Name:	Ammonia (anhydrous)
CAS Number:	7664-41-7
Flammable/Toxic:	Toxic

Accident History ID: Accident 3

Date of Accident:	May 1999
Time Accident Began (HH:MM):	15:15
NAICS Code of Process Involved:	311421
NAICS Description:	Fruit and Vegetable Canning
Release Duration:	001 Hours 45 Minutes

Release Event

Gas Release:	Yes
Liquid Spill/Evaporation:	N/A
Fire:	N/A
Explosion:	N/A
Uncontrolled/Runaway Reaction:	N/A

Release Source

Storage Vessel:	Yes
Piping:	N/A
Process Vessel:	N/A
Transfer Hose:	N/A
Valve:	Yes
Pump:	N/A
Joint:	N/A
Other Release Source:	Pressure relief valve discharge

Weather Conditions at the Time of Event

Wind Speed:	N/A
Units:	Meters/second
Direction:	N/A
Temperature:	N/A
Atmospheric Stability Class:	N/A
Precipitation Present:	N/A
Unknown Weather Conditions:	Yes

On-Site Impacts

Employee or Contractor Deaths:	0
Public Responder Deaths:	0
Public Deaths:	0
Employee or Contractor Injuries:	0
Public Responder Injuries:	0
Public Injuries:	0
On-Site Property Damage (\$):	0

Known Off-Site Impacts

Deaths:	0
Hospitalizations:	0
Public Deaths:	0
Other Medical Treatments:	0
Evacuated:	0
Sheltered-in-Place:	0
Off-Site Property Damage (\$):	0

Environmental Damage

Fish or Animal Kills:	N/A
Tree, Lawn, Shrub, or Crop Damage:	N/A
Water Contamination:	N/A
Soil Contamination:	N/A
Other Environmental Damage:	No environmental damage of any kind

Initiating Event

Initiating Event:	Equipment Failure
-------------------	-------------------

Contributing Factors

Equipment Failure:	Yes
Human Error:	N/A
Improper Procedures:	N/A
Overpressurization:	Yes
Upset Condition:	N/A
By-Pass Condition:	N/A
Maintenance Activity/Inactivity:	Yes
Process Design Failure:	N/A
Unsuitable Equipment:	N/A
Unusual Weather Condition:	N/A
Management Error:	N/A
Other Contributing Factor:	Compressor high pressure cut-outs set too high.

Off-Site Responders Notified

Off-Site Responders Notified:	Notified and Responded
-------------------------------	------------------------

Changes Introduced as a Result of the Accident

Improved or Upgraded Equipment:	Yes
Revised Maintenance:	Yes
Revised Training:	Yes
Revised Operating Procedures:	Yes
New Process Controls:	N/A
New Mitigation Systems:	N/A
Revised Emergency Response Plan:	Yes
Changed Process:	N/A
Reduced Inventory:	N/A
None:	N/A
Other Changes Introduced:	Replaced condenser with higher efficiency/capacity unit; instituted preventive maintenance program; replaced relief valves with newer models; re-piped lines to safer location.

Chemicals in Accident History

Quantity Released (lbs):	90
Percent Weight:	99.9
Chemical Name:	Ammonia (anhydrous)
CAS Number:	7664-41-7
Flammable/Toxic:	Toxic

Section 9. Emergency Response

Written Emergency Response (ER) Plan

Community Plan (Is facility included in written community emergency response plan?):	Yes
Facility Plan (Does facility have its own written emergency response plan?):	N/A
Response Actions (Does ER plan include specific actions to be taken in response to accidental releases of regulated substance(s)?):	N/A
Public Information (Does ER plan include procedures for informing the public and local agencies responding to accidental release?):	N/A
Healthcare (Does facility's ER plan include information on emergency health care?):	N/A

Local Agency

Agency Name (Name of local agency
with which the facility ER plan or
response activities are coordinated):

Melrose Park Fire Department

Agency Phone Number (Phone number
of local agency with which the facility
ER plan or response activities are
coordinated):

(708) 344-1210