

Section 1. Registration Information

Source Identification

Facility Name:	Pawtucket Power Associates, LP
Parent Company #1 Name:	Maxim Power Corp
Submission Type:	Resubmission
Receipt Date:	June 2009
Status:	Deregistered
Deregistration Effective Date:	December 2013

Facility Identification

Facility ID:	1000 0008 6845
--------------	----------------

Dun and Bradstreet Numbers (DUNS)

Facility DUNS:	N/A
----------------	-----

Facility Location Address

Street 1:	181 Concord Street
Street 2:	N/A
City:	Pawtucket
State:	RI
ZIP:	02860
ZIP4:	N/A
County:	Providence

Facility Latitude and Longitude

Latitude (decimal):	41.861296
Longitude (decimal):	-071.406952

Local Emergency Planning Committee and Regulations

LEPC:	District 1 LEPC
OSHA PSM:	Yes
EPCRA 302:	Yes
CAA Title V:	Yes

Process Chemicals

Program Level:	Program Level 3 process
Chemical Name:	Ammonia (anhydrous)
CAS Number:	7664-41-7
Flammable/Toxic:	Toxic
Program Level:	Program Level 2 process
Chemical Name:	Ammonia (conc 20% or greater)
CAS Number:	7664-41-7
Flammable/Toxic:	Toxic

Process NAICS

NAICS Code:	22111
NAICS Description:	Electric Power Generation

Section 6. Accident History

Accident History ID: Accident 1

Date of Accident:	June 2010
Time Accident Began (HH:MM):	16:40
NAICS Code of Process Involved:	221112
NAICS Description:	Fossil Fuel Electric Power Generation
Release Duration:	001 Hours 00 Minutes

Release Event

Gas Release:	Yes
Liquid Spill/Evaporation:	N/A
Fire:	N/A
Explosion:	N/A
Uncontrolled/Runaway Reaction:	N/A

Release Source

Storage Vessel:	N/A
Piping:	N/A
Process Vessel:	Yes
Transfer Hose:	N/A
Valve:	N/A
Pump:	N/A
Joint:	N/A
Other Release Source:	Failed O-ring on an oiler cup on the "B" accumulator recycle pump

Weather Conditions at the Time of Event

Wind Speed:	4.0
Units:	Miles/h
Direction:	N
Temperature:	82
Atmospheric Stability Class:	N/A
Precipitation Present:	N/A
Unknown Weather Conditions:	N/A

On-Site Impacts

Employee or Contractor Deaths:	0
Public Responder Deaths:	0
Public Deaths:	0
Employee or Contractor Injuries:	0
Public Responder Injuries:	0
Public Injuries:	0
On-Site Property Damage (\$):	0

Known Off-Site Impacts

Deaths:	0
Hospitalizations:	0
Public Deaths:	0
Other Medical Treatments:	0
Evacuated:	0
Sheltered-in-Place:	0
Off-Site Property Damage (\$):	0

Environmental Damage

Fish or Animal Kills:	N/A
Tree, Lawn, Shrub, or Crop Damage:	N/A
Water Contamination:	N/A
Soil Contamination:	N/A
Other Environmental Damage:	N/A

Initiating Event

Initiating Event:	Equipment Failure
-------------------	-------------------

Contributing Factors

Equipment Failure:	Yes
Human Error:	N/A
Improper Procedures:	N/A
Overpressurization:	N/A
Upset Condition:	N/A
By-Pass Condition:	N/A
Maintenance Activity/Inactivity:	N/A
Process Design Failure:	N/A
Unsuitable Equipment:	N/A
Unusual Weather Condition:	N/A
Management Error:	N/A
Other Contributing Factor:	N/A

Off-Site Responders Notified

Off-Site Responders Notified:	Notified and Responded
-------------------------------	------------------------

Changes Introduced as a Result of the Accident

Improved or Upgraded Equipment:	N/A
Revised Maintenance:	N/A
Revised Training:	N/A
Revised Operating Procedures:	N/A
New Process Controls:	N/A
New Mitigation Systems:	N/A
Revised Emergency Response Plan:	N/A
Changed Process:	N/A
Reduced Inventory:	N/A
None:	N/A
Other Changes Introduced:	Unknown

Chemicals in Accident History

Quantity Released (lbs):	100
Percent Weight:	100
Chemical Name:	Ammonia (anhydrous)
CAS Number:	7664-41-7
Flammable/Toxic:	Toxic

Accident History ID: Accident 2

Date of Accident:	April 2010
Time Accident Began (HH:MM):	12:31
NAICS Code of Process Involved:	221112
NAICS Description:	Fossil Fuel Electric Power Generation
Release Duration:	000 Hours 06 Minutes

Release Event

Gas Release:	Yes
Liquid Spill/Evaporation:	N/A
Fire:	N/A
Explosion:	N/A
Uncontrolled/Runaway Reaction:	N/A

Release Source

Storage Vessel:	N/A
Piping:	N/A
Process Vessel:	Yes
Transfer Hose:	N/A
Valve:	N/A
Pump:	N/A
Joint:	N/A
Other Release Source:	Site glass

Weather Conditions at the Time of Event

Wind Speed:	3.0
Units:	Miles/h
Direction:	ENE
Temperature:	52
Atmospheric Stability Class:	N/A
Precipitation Present:	N/A
Unknown Weather Conditions:	N/A

On-Site Impacts

Employee or Contractor Deaths:	0
Public Responder Deaths:	0
Public Deaths:	0
Employee or Contractor Injuries:	1
Public Responder Injuries:	0
Public Injuries:	0
On-Site Property Damage (\$):	0

Known Off-Site Impacts

Deaths:	0
Hospitalizations:	0
Public Deaths:	0
Other Medical Treatments:	0
Evacuated:	0
Sheltered-in-Place:	0
Off-Site Property Damage (\$):	0

Environmental Damage

Fish or Animal Kills:	N/A
Tree, Lawn, Shrub, or Crop Damage:	N/A
Water Contamination:	N/A
Soil Contamination:	N/A
Other Environmental Damage:	N/A

Initiating Event

Initiating Event:	Equipment Failure
-------------------	-------------------

Contributing Factors

Equipment Failure:	Yes
Human Error:	N/A
Improper Procedures:	N/A
Overpressurization:	N/A
Upset Condition:	N/A
By-Pass Condition:	N/A
Maintenance Activity/Inactivity:	N/A
Process Design Failure:	N/A
Unsuitable Equipment:	N/A
Unusual Weather Condition:	N/A
Management Error:	N/A
Other Contributing Factor:	N/A

Off-Site Responders Notified

Off-Site Responders Notified:	Notified and Responded
-------------------------------	------------------------

Changes Introduced as a Result of the Accident

Improved or Upgraded Equipment:	N/A
Revised Maintenance:	N/A
Revised Training:	N/A
Revised Operating Procedures:	N/A
New Process Controls:	N/A
New Mitigation Systems:	N/A
Revised Emergency Response Plan:	N/A
Changed Process:	N/A
Reduced Inventory:	N/A
None:	N/A
Other Changes Introduced:	Requested and received design documentation from OEM, performed ultrasonic testing on ammonia piping, installed eye wash station in vicinity of chiller building

Chemicals in Accident History

Quantity Released (lbs):	10
Percent Weight:	100
Chemical Name:	Ammonia (anhydrous)
CAS Number:	7664-41-7
Flammable/Toxic:	Toxic

Section 9. Emergency Response

Written Emergency Response (ER) Plan

Community Plan (Is facility included in written community emergency response plan?):	Yes
Facility Plan (Does facility have its own written emergency response plan?):	Yes
Response Actions (Does ER plan include specific actions to be taken in response to accidental releases of regulated substance(s)?):	Yes
Public Information (Does ER plan include procedures for informing the public and local agencies responding to accidental release?):	Yes
Healthcare (Does facility's ER plan include information on emergency health care?):	Yes

Local Agency

Agency Name (Name of local agency with which the facility ER plan or response activities are coordinated):	Pawtucket Fire Department
Agency Phone Number (Phone number of local agency with which the facility ER plan or response activities are coordinated):	(401) 725-1420