

## Section 1. Registration Information

### Source Identification

---

Facility Name:	West Shore Regional Water Treatment Plant
Parent Company #1 Name:	Pennsylvania American Water
Submission Type:	Resubmission
Receipt Date:	March 2020
Status:	Deregistered
Deregistration Effective Date:	April 2021

### Facility Identification

---

Facility ID:	1000 0019 4586
--------------	----------------

### Dun and Bradstreet Numbers (DUNS)

---

Facility DUNS:	N/A
----------------	-----

### Facility Location Address

---

Street 1:	275 Steigerwalt Hollow Road
Street 2:	N/A
City:	New Cumberland
State:	PA
ZIP:	17070
ZIP4:	N/A
County:	York

### Facility Latitude and Longitude

---

Latitude (decimal):	40.201111
Longitude (decimal):	-076.878056

### Local Emergency Planning Committee and Regulations

---

LEPC:	York County LEPC
OSHA PSM:	Yes
EPCRA 302:	Yes
CAA Title V:	N/A

## Process Chemicals

---

Program Level:	Program Level 3 process
Chemical Name:	Chlorine
CAS Number:	7782-50-5
Flammable/Toxic:	Toxic

## Process NAICS

---

NAICS Code:	22131
NAICS Description:	Water Supply and Irrigation Systems

## Section 6. Accident History

No records found.

## Section 9. Emergency Response

### Written Emergency Response (ER) Plan

---

Community Plan (Is facility included in written community emergency response plan?):	Yes
Facility Plan (Does facility have its own written emergency response plan?):	Yes
Response Actions (Does ER plan include specific actions to be taken in response to accidental releases of regulated substance(s)?):	Yes
Public Information (Does ER plan include procedures for informing the public and local agencies responding to accidental release?):	Yes
Healthcare (Does facility's ER plan include information on emergency health care?):	Yes

### Local Agency

---

Agency Name (Name of local agency with which the facility ER plan or response activities are coordinated):	York County LEPC
Agency Phone Number (Phone number of local agency with which the facility ER plan or response activities are coordinated):	(717) 840-7494