

HCAL developments for Jets and MET

Edmund A. Berry

Friday, August 22, 2014



BROWN

Section 1

Introduction

Introduction

- Changes between the Run 1 and Run 2 physics environments are well-documented
- HCAL has implemented hardware upgrades in response
- Software updates must:
 - Account for hardware changes (e.g. recalibration)
 - Respond to physics changes in Run 2 environment

HCAL hardware upgrades during LS1

- HB and HE:
 - Replaced clock, control, monitor modules
 - Removes synchronization problems with isolated sections of HB and HE
- HO
 - Changed hybrid photodiodes to silicon photomultipliers
 - Improves signal to noise for MIPs in HO
- HF
 - Replaced single-anode photomultiplier tubes (PMTs) with thin window multi-anode PMTs
 - Also: installed new cables capable of dual readout
 - Reduces fake signal from PMT window hits

HCAL software responses

HCAL software is responding in many ways,
all of which affect jets and MET

I will discuss three in particular:

- 1 Calibration
- 2 Reconstruction
- 3 Noise filters

Section 2

Calibration

Calibration scope and priorities

- Tuning and development (**now - end 2014**)
 - Address HCAL shortcomings revealed during Run 1
 - Tune existing Run 1 methods for Run 2 environment
 - Develop new methods when necessary
- Preparing HCAL pre-calibration, (**end 2014, 2 months**)

Relying on:


 - Radioactive source calibration: critical for HF startup calibration
 - Cosmics: very effective tool for HO calibration
 - Splashes: useful in 2009 and 2010 for HBHE, not essential in 2015
- Integration of HCAL tools with AICa (**CMSSW_7_3_X**)
 - **If necessary**

Calibration outline

Three main areas of focus:


- 1 Radiation damage correction
- 2 ϕ symmetry calibration
- 3 Absolute energy calibration:
 - HB & part of HE: single particle (IsoTracks)
 - HE (& perhaps elsewhere): dijet, γ -jet
 - HF: $Z \rightarrow ee$
 - HO: muons (GeV/MIP sets the scale)

- Conveners: Jordan Damgov and Yurii Maravin




Radiation damage in the HE: how we know it

- In Run 1, radiation damage was monitored with laser measurements
- In 2012, an additional method using pp data with physics triggers was introduced




Radiation damage in the HB: what we know today




- Ratio of signal from HB Co-60 calibration (2014/2005)
- $2 \times 20^\circ$ wedges on HB-: **April, 2014**
- Consistent with 5% damage to L1 of HB

Radiation damage in the HB: how we know it



- Laser monitoring can't monitor radiation damage to front layers of HB
- Co-60 calibration (2005, 2014) is the only way to learn about radiation damage to front layers of HB

Radiation damage in the HB: how to deal with it



- More data needed to establish effect beyond stat. fluct.
- Since HB only has 1 depth (unlike HE with 2-3 depths), layer-dependent damage can only be corrected on average, introducing an energy dependence
- Effect can probably be removed by MC corrections.

Radiation damage: what to do about it

- Current plan for HE:
 - Use updated laser measurement algo. and updated laser
 - Use pp data as a less-frequent cross-check
 - First year of Run 2: expect signal loss similar to Run 1
- Current plan for HB:
 - Data suggests layer-dependent radiation damage at 5%
 - More data needed to establish effect beyond stat. fluct.
 - Continue Co-60 sourcing campaign on HB (**Friday**)
 - 4 additional HB wedges to be sourced
- Correct 2015 data at all levels (L1, HLT, Offline)

ϕ symmetry calibration

- Goal: equalize response in ϕ for η -rings with 2 methods:
- Method of moments
 - Non-zero-suppressed and non-HCAL triggers
 - Worse precision in the HB than iterative method
 - ~ 5 million events yields $\sim 2\%$ precision
- Iterative method
 - non-HCAL physics triggers
 - Better precision in the HB than moments method
 - 60 million events yields: 1% HB; 0.2-2.5% HE; 0.3% HF
- Work on both methods is ongoing for Run 2 environment

Absolute HB/HE energy calibration: single particle

- Method for calibration with isolated tracks
- Tracker provides precision momentum measurement
- Require:
 - Good quality tracks reaching ECAL and HCAL
 - Tracks are isolated w.r.t. ECAL energy and other tracks
- Preparing estimates on precision for Run 2 environment
- No IsoTrack trigger coverage in high η HE region


Absolute HE energy scale: dijet balancing

- Method for ring-by-ring calibration with dijet events
- Building on work done by JP Chou ([talk](#), [IN2008/046](#))
- Require:
 - Two PFJets with small $|\Delta\eta|$: i.e. two PFJets in the same part of the jet energy response curve
 - Remove PU using PFJets
 - Need to disambiguate energy corrections
 - Working with PF experts

Absolute HF energy scale: $Z \rightarrow ee$

- 2011 method: DN2011/012
- Require:
 - Precision tag electron in the ECAL with tracking
 - Probe electron in the HF
- For 2015 running:
 - Special trigger needed to collect data at $|\eta| > 4.0$
 - Performance evaluated with CSA14 samples

Results from 2012



Section 3

Reconstruction

Reconstruction scope and priorities

- Primary goal is to develop an algorithm for OOT PU mitigation in 25 ns running (**now**)
 - A baseline algorithm is ready for CMSSW_7_2_0
 - Fine-tuning is ongoing
 - Improvements could go into CMSSW_7_3_0 (**Nov. 10**)
- Develop alternative algorithms (until **Dec. 2014**)
- If we have more than one working algorithm, make a choice for data taking


Reconstruction outline

Main areas of focus:

- 1 Baseline method (complete, improvements ongoing)
- 2 Alternative method (in development)




■ Convener: Artur Apresyan → Stephanie Brandt

Reconstruction: baseline method



- Algorithm parameterizes pulse shape as function of charge in triggered TS
 - Step 1: Measure shape in data for given $|\eta|$ regions
 - Step 2: Use pulse shape to subtract OOT pulses
- Status:
 - Baseline method **validated and ready** for CMSSW_7_2_0
 - See [talk](#) by [Artur Apresyan](#)
 - Work is not done! New algorithms are under study!

Reconstruction: alternative method



- Also, new method being investigated by the MIT group
 - Step 1: fit pulse shape for arrival time and total charge
 - Step 2: use fit to estimate the OOT PU contamination in energy when there are two pulses
- Still in development stage, but manpower is present
- Regular status updates in HCAL reconstruction working group

Section 4

Noise filters

Noise filters scope and priorities

- Noise filters that worked in Run 1 need to be updated for the Run 2 environment
- These updates are under development, and the results are encouraging
- Note that these noise filters may change a bit with the reconstruction algorithm

Noise filters outline



Main areas of focus:

- 1 R45 upgrade filter
- 2 Negative energy filter
- 3 Validation on data and MC & implementation in CMSSW

■ Convener: Yi Chen


R45 upgrade filter

- $R45 = \frac{TS4 - TS5}{TS4 + TS5}$ used in 2012 to identify RBX noise
- New method needed for 25 ns
- An RBX with a large fraction of energy coming from “noisy” RecHits is suspect
- Initial results encouraging
- Need more work to finalize version in CMSSW




Negative energy filter

- New HCAL reconstruction corrects for expected tail from previous time samples
- For spike-like noise, reconstructed energy from TS6 can be negative
- Initial results encouraging (see plot for data, right)
- Need more work to finalize version in CMSSW



OOT PU-corrected TS6 in data



Section 5

Conclusion

Conclusion

- HCAL is preparing for data taking in 2015
- Lots of new developments are underway:
 - New/updated calibration efforts
 - New/updated noise filtering algorithms
 - New OOT PU mitigation algorithms
- Some improvements are already in place
- Other improvements are coming soon
- Questions are welcome