



HNIR.GuideInfo Power-limited Fire Alarm Cable

[View Listings](#)[Page Bottom](#)

[Fire Alarm Cable] Power-limited Fire Alarm Cable

[See General Information for Fire Alarm Cable](#)

USE AND INSTALLATION

This category covers power-limited fire alarm cable intended for use in power-limited circuits in accordance with Article 760 of ANSI/NFPA 70, "National Electrical Code" (NEC).

Unless a higher temperature rating is marked on the cable, power-limited fire alarm cable is intended for use where operating temperature does not exceed 60°C. The voltage rating is 300 V but is not marked.

PRODUCT MARKINGS

Power-limited fire alarm cable is identified by a marking on the surface of the jacket or on a marker tape under the jacket. This marking includes one of the following Type designations:

FPL — Indicates cable intended for use within buildings in accordance with Section 760.154(C) of the NEC. This cable does not spread flame to the top of the tray in the Vertical-Tray Flame Test in [ANSI/UL 1685](#), "Vertical-Tray Fire-Propagation and Smoke-Release Test for Electrical and Optical-Fiber Cables."

FPLP — Indicates cable intended for use within buildings in ducts or plenums or other spaces used for environmental air in accordance with Section 760.154(A) of the NEC. This cable exhibits a maximum peak optical density of 0.5, a maximum average optical density of 0.15, and a maximum flame spread distance of 5 ft when tested per ANSI/NFPA 262, "Standard Method of Test for Flame Travel and Smoke of Wires and Cables for Use in Air-Handling Spaces."

FPLR — Indicates cable intended for use within buildings in vertical shafts in accordance with Section 760.154(B) of the NEC. The flame propagation height of this cable is less than 12 ft when tested per [ANSI/UL 1666](#), "Test for Flame Propagation Height of Electrical and Optical-Fiber Cables Installed Vertically in Shafts."

Power-limited Fire Alarm Cable — Indicates cable suitable for use within buildings (1) where the cable is enclosed in a raceway, or (2) in nonconcealed spaces where the exposed length of cable does not exceed 10 ft, in accordance with Sections 760.154(C)(2) and (3) of the NEC. This cable complies with the VW-1 Flame Test requirements in [ANSI/UL 1581](#).

Certified Type FPLP cable that is additionally marked "Also Certified NYC CERT Fire Alarm Cable" has been investigated in accordance with the requirements of the Fire Alarm Code of the Department of Buildings of the City of New York.

Cable that complies with the requirements for "Limited Combustible" specified in ANSI/NFPA 90A, "Installation of Air Conditioning and Ventilating Systems," is surface marked "Limited Combustible."

Cable marked "direct burial," "for direct burial" or "dir bur" has been investigated and found suitable for direct burial in the earth.

Cable marked "sunlight resistant" or "sun res" may be exposed to the direct rays of the sun.

Cable marked "CI (max voltage ____)" is suitable for use as circuit-integrity cable at the maximum voltage to ground indicated, in accordance with Section 760.179(G) of the NEC.

Cable marked "CI (max voltage ____)" is intended for use in free air only.

Cable marked "wet" or "wet location" is suitable for use in wet locations.

Cable marked "-30C," "-40C," "-50C," "-60C" or "-70C" complies with a cold bend test conducted at that temperature.

PRODUCT IDENTITY

The following product identity may appear on the product:

Power-limited Fire Alarm Cable

ADDITIONAL INFORMATION

For additional information, see Electrical Equipment for Use in Ordinary Locations ([AALZ](#)).

REQUIREMENTS

The basic standard used to investigate products in this category is [ANSI/UL 1424](#), "Cables for Power-Limited Fire-Alarm Circuits."

UL MARK

The UL symbol on the product and the Certification Mark of UL on the attached tag, reel, or on the smallest unit container in which the product is packaged is the only method provided by UL to identify products manufactured under its Certification and Follow-Up Service. The [Certification Mark](#) for these products includes the UL symbol, the words "CERTIFIED" and "SAFETY," the geographic identifier(s), and a file number.

In addition, the Certification Mark for cable also certified for use in accordance with the requirements of the Fire Alarm Code of the Department of Buildings of the City of New York includes the statement "Also Certified for Use as Fire Alarm Cable in New York

City."

The Certification Mark for this category requires the use of a holographic label.

Alternate UL Mark

The UL symbol on the product and the Listing Mark of UL on the attached tag, the reel, or the smallest unit container in which the product is packaged is the only method provided by UL to identify products manufactured under its Listing and Follow-Up Service. The Listing Mark for these products includes the UL symbol (as illustrated in the Introduction of this Directory) together with the word "LISTED," a control number, and the product name "Power-limited Fire Alarm Cable."

In addition, the Listing Mark for cable also Classified for use in accordance with the requirements of the Fire Alarm Code of the Department of Buildings of the City of New York includes the statement "Also Classified for Use as Fire Alarm Cable in New York City."

The Listing Mark for this category requires the use of a holographic label.

UL, in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. UL shall not incur any obligation or liability for any loss, expense or damages, including incidental or consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Guide Information.

Last Updated on 2013-05-16

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2013 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2013 UL LLC".