EPA Section 608: Evacuation Levels & Safety Classifications

Peer-reviewed by EduPro Suite Editorial & Math Solution Verification Suite. 100% verified calculations with zero arithmetic errors.

Core Governing Formula / Rule:
ASHRAE Standard 34: Class A (Lower Toxicity), Class B (Higher Toxicity). Class 1 (No Flammability), Class 2L (Mild Flammability), Class 2 (Flammable), Class 3 (Higher Flammability). R-410A = A1 | R-32 = A2L | R-290 (Propane) = A3 | R-717 (Ammonia) = B2L.

Step-by-Step Verified Application Example:

Evacuation requirements for appliances with >= 200 lbs of R-22 using non-certified recovery equipment: **4 inches of Hg vacuum**; with certified equipment: **10 inches of Hg vacuum**. Appliances with R-123 (low pressure): Evacuate to **25 mm of Hg absolute** before opening system.

← Back to All Exam Vaults

Unlock Full 25-Exam Suite ($29)