

Infiltration/Exfiltration

- Unintended outdoor air leaking into (infiltration) or out of (exfiltration) the building
- Empirically determined by performing a blower door test, where the building is pressurized and depressurized to reach a pressure differential (50Pa for houses). The flowrate to maintain that differential is the air leakage rate, expressed as the Power law

$$Q = C (\Delta P)^n$$

$$Q - \text{flowrate in } \frac{L}{s \cdot m^2}$$

$$C - \text{flow coefficient in } \frac{L}{s \cdot m^2 \cdot Pa^n}; \text{ building specific}$$

$$\Delta P - \text{pressure differential in Pa}$$

$$n - \text{pressure coefficient } (\sim 0.67 \text{ for most buildings})$$

- Other ways to characterize the leakage is usually expressed as:
 - Air change per hour @ 50 Pa
 - Flow coefficient
 - Effective leakage area
- The effective leakage area converts the leakage rate of a building to an equivalent opening (i.e. summing the area of all cracks/gaps)

$$A_L = 10000 Q_{\Delta P} \frac{\sqrt{\rho/2\Delta P}}{C_d}$$

$$A_L - \text{equivalent leakage area [cm}^2\text{] at } \Delta P \text{ [Pa]}$$

$$Q_{\Delta P} - \text{air leakage rate at } \Delta P \left[\frac{m^3}{s} \right]$$

$$\rho - \text{density of the air } \left[\frac{kg}{m^3} \right]$$

$$\Delta P_r C_d - \text{discharge coefficient} = 1$$

Infiltration modelling OpenStudio

The infiltration is modelled using the effective leakage area model:

$$Infiltration = (F_{Schedule}) \frac{A_L}{1000} \sqrt{C_s \Delta T + C_w (WindSpeed)^2}$$

$$F_{Schedule} - \text{is a schedule value (0 to 1) [-]}$$

$$A_L - \text{equivalent leakage area [cm}^2\text{] at 4 Pa}$$

$$\Delta T - \text{indoor - outdoor temperature difference}$$

$$C_s \text{ and } C_w - \text{stack and wind coefficient [-]}$$

This equation is different from the previous equation used to estimate the A_L based on blower door test results because this equation accounts for stack and wind effects in operation.

In order to use this model, the blower door test result 1 ACH @ 50 Pa needs to be translated into $A_{L, 4 Pa}$.

First, convert the ACH to a flowrate,

$$\text{Volume of building (excl. garage)} = 676.07 \text{ m}^3 \rightarrow Q_{50 Pa} = 676.07 \frac{\text{m}^3}{\text{hr}} = 0.188 \frac{\text{m}^3}{\text{s}}$$

The blower door test results can be characterized as

$$Q_{50 Pa} = C_{50} (10)^n$$

Similarly, the 4 Pa infiltration rate can be characterized as

$$Q_{4 Pa} = C_4 (4)^n$$

Some manipulation yields

$$\frac{Q_{50 Pa}}{Q_{4 Pa}} = \frac{C_{50} (50)^n}{C_4 (4)^n}$$

Assume

$$C_{10} = C_4 \text{ and } n = 0.67$$

Then

$$Q_{4 Pa} = Q_{50 Pa} \frac{C_4 (4)^n}{C_{50} (50)^n}$$

$$Q_{4 Pa} = (0.188) \frac{4^{0.67}}{50}$$

$$Q_{4 Pa} = 0.0346 \frac{\text{m}^3}{\text{s}}$$

Substituting it into the equation for estimating the effective leakage area, yields

$$A_L = 134.052 \text{ cm}^2 @ 4 Pa$$