



PRIME WEST BUILDING

PRIME WEST BUILDING PTY LTD

ABN: 36 645 254 422

U16/63, Knutsford Ave, Rivervale, 6103

Email: info@primewestbuilding.com.au

TEL: 0477788011

TAX INVOICE

INV-101412

Invoice Date: 30/04/2026

Claim Number : V/O-01

Due Date: 30/05/2026

BILL TO

Welink Construction Pty Ltd

U32, 269 Vincent Street Leederville WA, 6007

PROJECT

ECONOLODGE MOTEL STAGE 2

85 Great Eastern Hwy, Rivervale WA 6103

DESCRIPTION

TOTAL

Variation works - V/O- 01

Detail 8, of Drawing A1001

\$6,620.00

Provide and install fire batts between the internal concrete wall and roof sheeting

As per the email quotation dated 21/03/2025

From: brian@primewestbuilding.com.au <brian@primewestbuilding.com.au>

Sent: Friday, 21 March 2025 12:02 AM

To: 'Michael Cheeseman' <michael@welink.com.au>

Subject: RE: Econolodge Stage 2 : Fire Pressure Test Econolodge

Hi Michael,

Please see comment below:

- If the floor, wall and ceiling finishes are available, pls provide a copy of the fire test indices report to ensure they BCA requirements

Kindly review the attachments; I hope this aligns with the certifier's requirements.;

- Detail 8, of Drawing A1001 – pls allow for fire batts to be provided between concrete wall and roof sheeting.

Material to be used: **Bradford Fire seal Insulation Party Wall Batts,**

Provide and install fire batts between the internal concrete wall and roof sheeting, cost: **\$6620.00**

NOT APPROVED

This variation is not approved -
confirmed with MC

Payment Details

Bank: Common Wealth

Account Name: PRIME WEST BUILDING

BSB: 066-128 | Account Number: 1078 5927

Total Excl. Gst: \$6,620.00

GST: \$662.00

Amount Due Incl. Gst: \$ 7,282.00

Thank you for your business!