

Reports

[Print](#)

Monthly Billing Summary Report

10/04/2012 - 11/01/2012

Dominion Virginia Power

Account Name(s): CITY OF ALEXANDRIA**Account Number:** 4452642962**Service Address:** 3600 WHEELER AVE
ALEXANDRIA, VA 22304**Rate Schedule:** Schedule 130**Start Date & Time:** 10/04/2012 00:00:00**Number of Days:** 29**Stop Date & Time:** 11/01/2012 23:59:59**Recorder ID:** 02123016

Determination of On and Off Peak Hours

Please refer to the on-peak and off-peak hours listed in your rate schedule

Total KWh: 224005**Total On-Peak kWh:** 108620**Total Off-Peak kWh:** 115385

Highest On-Peak kW Demands for the Billing Period

Date:	On-Peak kW:	Time:
10/04/2012	478.2	1030
10/04/2012	474.4	1330
10/04/2012	473.9	1200
10/04/2012	472.2	1000
10/04/2012	468.7	1230

Highest Off-Peak kW Demands for the Billing Period

Date:	Off-Peak kW:	Time:
10/14/2012	438.5	1500
10/04/2012	437.9	0530
10/04/2012	434.2	0630
10/04/2012	431.2	0600
10/04/2012	426.3	0100

PEAK KVAR (Lead)

KVAR:	kW:	KVA:	Date:	Interval:
-40.1	300.0	302.6	10/11/2012	0900
-39.0	296.5	299.0	10/11/2012	1130
-36.0	299.4	301.6	10/11/2012	0830
-35.2	303.5	305.5	10/11/2012	1030
-35.2	297.5	299.6	10/17/2012	0900

PEAK KVAR (Lag)

KVAR:	kW:	KVA:	Date:	Interval:
112.4	474.4	487.5	10/04/2012	1330
109.1	454.1	467.1	10/04/2012	1530
106.2	370.2	385.1	10/14/2012	1100
105.8	375.0	389.7	10/09/2012	1530
103.2	370.4	384.5	10/14/2012	1230

CHANNEL/METER VERIFICATION

Channel Information

Channel #:	Channel Pulses:	Pulse Multiplier:	Channel Total:	UOM:
01	1659296	0.135	224005	KWH
02	1015511	0.135	137094	KQH

Meter Information

Meter #:	Start	Stop	Difference:	Meter	Meter	UOM:
----------	-------	------	-------------	-------	-------	------

Meter #:	Start	Stop	Difference:	Meter	Meter	UOM:
	Reading:	Reading:		Multiplier:	Total:	
0004958745	8372	9118	746.0	300	223800	KWH
0004958745	5021	5478	457.0	300	137100	KQH

Note: To convert kW readings to kWh divide by 2.
A value of zero may indicate that this measurement is not recorded under the rate plan.

* Billing adjustments, meter exchanges and rounding in calculations may cause a discrepancy in Total kWh, Total On-Peak and Total Off-Peak kWh figures displayed on this summary report.