

Reports

[Print](#)

Monthly Billing Summary Report

02/06/2013 - 03/06/2013

Dominion Virginia Power

Account Name(s): CITY OF ALEXANDRIA**Account Number:** 4452642962**Service Address:** 3600 WHEELER AVE
ALEXANDRIA, VA 22304**Rate Schedule:** Schedule 130**Start Date & Time:** 02/06/2013 00:00:00**Number of Days:** 29**Stop Date & Time:** 03/06/2013 23:59:59**Recorder ID:** 02123016

Determination of On and Off Peak Hours

Please refer to the on-peak and off-peak hours listed in your rate schedule

Total KWh: 229660**Total On-Peak kWh:** 109485**Total Off-Peak kWh:** 120175

Highest On-Peak kW Demands for the Billing Period

Date:	On-Peak kW:	Time:
02/26/2013	389.9	1300
02/26/2013	388.8	1130
02/26/2013	388	1400
02/19/2013	386.4	1130
02/26/2013	385.8	1230

Highest Off-Peak kW Demands for the Billing Period

Date:	Off-Peak kW:	Time:
02/15/2013	350.5	0630
03/06/2013	349.7	0600
02/06/2013	348	0630
02/14/2013	348	0600
02/14/2013	347	0630

PEAK KVAR (Lead)

KVAR:	kW:	KVA:	Date:	Interval:
-54.9	346.7	351.0	03/06/2013	0930
-50.0	354.0	357.5	03/06/2013	1100
-46.1	352.1	355.1	03/06/2013	1000
-41.8	344.5	347.0	03/06/2013	1200
-40.7	349.1	351.5	03/06/2013	1030

PEAK KVAR (Lag)

KVAR:	kW:	KVA:	Date:	Interval:
77.0	320.8	329.9	02/15/2013	2100
76.1	321.8	330.7	02/22/2013	2300
72.5	317.3	325.4	02/25/2013	2130
71.6	322.1	330.0	03/01/2013	2130
71.2	298.9	307.3	02/24/2013	1500

CHANNEL/METER VERIFICATION

Channel Information

Channel #:	Channel Pulses:	Pulse Multiplier:	Channel Total:	UOM:
01	1701185	0.135	229660	KWH
02	996400	0.135	134514	KQH

Meter Information

Meter #:	Start	Stop	Difference:	Meter	Meter	UOM:
----------	-------	------	-------------	-------	-------	------

Meter #:	Start	Stop	Difference:	Meter	Meter	UOM:
	Reading:	Reading:		Multiplier:	Total:	
0004958745	11548	12314	766.0	300	229800	KWH
0004958745	6915	7364	449.0	300	134700	KQH

Note: To convert kW readings to kWh divide by 2.
A value of zero may indicate that this measurement is not recorded under the rate plan.

* Billing adjustments, meter exchanges and rounding in calculations may cause a discrepancy in Total kWh, Total On-Peak and Total Off-Peak kWh figures displayed on this summary report.