### Reports



## Monthly Billing Summary Report

03/07/2013 - 04/05/2013

#### **Dominion Virginia Power**

Account Name(s): CITY OF ALEXANDRIA

Account Number: 4452642962 Service Address: 3600 WHEELER AVE ALEXANDRIA, VA 22304

 Rate Schedule:
 Schedule 130
 Start Date & Time:
 03/07/2013 00:00:00

 Number of Days:
 30
 Stop Date & Time:
 04/05/2013 23:59:59

**Recorder ID:** 02123016

#### **Determination of On and Off Peak Hours**

Please refer to the on-peak and off-peak hours listed in your rate schedule

Total KWh: 235799 Total On-Peak kWh: 114785 Total Off-Peak kWh: 121014

# Highest On-Peak kW Demands for the Billing Period

Date:	On-Peak kW:	Time:
03/11/2013	418	1500
04/01/2013	411.5	1400
04/01/2013	407.7	1330
03/19/2013	404.5	1400
03/11/2013	394.7	1530

#### Highest Off-Peak kW Demands for the Billing Period

Date:	Off-Peak kW:	Time:
03/16/2013	374.8	1700
03/12/2013	372.6	0630
03/16/2013	370.7	1630
03/16/2013	366.1	1730
03/12/2013	362.1	0600

#### PEAK KVAR (Lead)

KVAR:	kW:	KVA:	Date:	Interval:
-49.1	317.8	321.6	03/17/2013	1830
-42.2	337.8	340.4	03/07/2013	1800
-33.4	325.6	327.3	03/16/2013	1830
-30.9	351.0	352.4	03/07/2013	0630
-30.7	344.8	346.2	03/07/2013	1730

#### PEAK KVAR (Lag)

KVAR:	kW:	KVA:	Date:	Interval:
94.5	418.0	428.5	03/11/2013	1500
94.2	407.7	418.4	04/01/2013	1330
89.5	394.7	404.8	03/11/2013	1530
87.8	362.6	373.1	03/11/2013	1930
87.0	373.7	383.7	03/11/2013	1630

#### **CHANNEL/METER VERIFICATION**

#### **Channel Information**

Channel #:	Channel Pulses:	Pulse Multiplier:	Channel Total:	UOM:
01	1746659	0.135	235799	KWH
02	1007015	0.135	135947	KQH

#### **Meter Information**

Makau # Chaub Chan Difference Makeu Makeu HOM-

метег #:	Start	Stop	иптегепсе:	метег	метег	UUM:
	Reading:	Reading:		Multiplier:	Total:	
0004958745	12314	13100	786.0	300	235800	KWH
0004958745	7364	7817	453.0	300	135900	KQH

Note: To convert kW readings to kWh divide by 2.

A value of zero may indicate that this measurement is not recorded under the rate plan.

<sup>\*</sup> Billing adjustments, meter exchanges and rounding in calculations may cause a discrepancy in Total kWh, Total On-Peak and Total Off-Peak kWh figures displayed on this summary report.