

Reports

[Print](#)

Monthly Billing Summary Report

07/06/2012 - 08/03/2012

Dominion Virginia Power

Account Name(s): CITY OF ALEXANDRIA**Account Number:** 4452642962**Service Address:** 3600 WHEELER AVE
ALEXANDRIA, VA 22304**Rate Schedule:** Schedule 130**Start Date & Time:** 07/06/2012 00:00:00**Number of Days:** 29**Stop Date & Time:** 08/03/2012 14:59:59**Recorder ID:** 02123016

Determination of On and Off Peak Hours

Please refer to the on-peak and off-peak hours listed in your rate schedule

Total KWh: 331066**Total On-Peak kWh:** 128154**Total Off-Peak kWh:** 202911

Highest On-Peak kW Demands for the Billing Period

Date:	On-Peak kW:	Time:
07/18/2012	630.5	1430
07/18/2012	625.6	1500
07/18/2012	622.6	1530
07/18/2012	619.1	1230
07/18/2012	619.1	1600

Highest Off-Peak kW Demands for the Billing Period

Date:	Off-Peak kW:	Time:
07/09/2012	637.2	0800
07/09/2012	629.9	0830
07/07/2012	608	1200
07/07/2012	595.9	1130
07/07/2012	592.7	1230

PEAK KVAR (Lead)

KVAR:	kW:	KVA:	Date:	Interval:
-46.9	533.3	535.3	07/10/2012	1830
-42.6	561.3	562.9	07/06/2012	1300
-40.8	476.8	478.6	07/11/2012	1830
-40.7	561.3	562.8	07/06/2012	1230
-40.5	564.8	566.3	07/06/2012	1430

PEAK KVAR (Lag)

KVAR:	kW:	KVA:	Date:	Interval:
191.1	608.0	637.4	07/07/2012	1200
187.2	595.9	624.6	07/07/2012	1130
173.3	554.0	580.5	07/07/2012	0200
172.3	571.1	596.5	07/07/2012	0030
171.9	584.6	609.3	07/07/2012	1030

CHANNEL/METER VERIFICATION

Channel Information

Channel #:	Channel Pulses:	Pulse Multiplier:	Channel Total:	UOM:
01	2452341	0.135	331066	KWH
02	1473281	0.135	198893	KQH

Meter Information

Meter #:	Start	Stop	Difference:	Meter	Meter	UOM:
----------	-------	------	-------------	-------	-------	------

Meter #:	Start	Stop	Difference:	Meter	Meter	UOM:
	Reading:	Reading:		Multiplier:	Total:	
0004958745	5267	6370	1103.0	300	330900	KWH
0004958745	3004	3666	662.0	300	198600	KQH

Note: To convert kW readings to kWh divide by 2.
A value of zero may indicate that this measurement is not recorded under the rate plan.

* Billing adjustments, meter exchanges and rounding in calculations may cause a discrepancy in Total kWh, Total On-Peak and Total Off-Peak kWh figures displayed on this summary report.