

Reports

[Print](#)

Monthly Billing Summary Report

12/05/2012 - 01/07/2013

Dominion Virginia Power

Account Name(s): CITY OF ALEXANDRIA**Account Number:** 4452642962**Service Address:** 3600 WHEELER AVE
ALEXANDRIA, VA 22304**Rate Schedule:** Schedule 130**Start Date & Time:** 12/05/2012 15:00:00**Number of Days:** 33**Stop Date & Time:** 01/07/2013 23:59:59**Recorder ID:** 02123016

Determination of On and Off Peak Hours

Please refer to the on-peak and off-peak hours listed in your rate schedule

Total KWh: 253193**Total On-Peak kWh:** 116905**Total Off-Peak kWh:** 136287

Highest On-Peak kW Demands for the Billing Period

Date:	On-Peak kW:	Time:
12/10/2012	423.1	1000
12/10/2012	418	0900
12/10/2012	414.2	1100
12/10/2012	400.1	1430
12/10/2012	399.9	0830

Highest Off-Peak kW Demands for the Billing Period

Date:	Off-Peak kW:	Time:
12/21/2012	365.9	0030
12/21/2012	362.9	0130
12/17/2012	359.9	2300
12/21/2012	359.1	0100
12/21/2012	356.4	0200

PEAK KVAR (Lead)

KVAR:	kW:	KVA:	Date:	Interval:
-42.6	334.5	337.2	01/07/2013	1630
-38.3	339.7	341.8	01/04/2013	1630
-32.1	327.2	328.8	01/07/2013	1700
-29.8	341.0	342.3	12/11/2012	0900
-29.2	329.1	330.4	12/11/2012	0800

PEAK KVAR (Lag)

KVAR:	kW:	KVA:	Date:	Interval:
102.3	353.7	368.2	12/21/2012	0230
97.0	334.8	348.6	12/18/2012	0300
96.6	343.4	356.8	12/21/2012	0300
96.2	346.4	359.5	12/18/2012	0100
94.8	324.0	337.6	12/18/2012	0330

CHANNEL/METER VERIFICATION

Channel Information

Channel #:	Channel Pulses:	Pulse Multiplier:	Channel Total:	UOM:
01	1875504	0.135	253193	KWH
02	1141363	0.135	154084	KQH

Meter Information

Meter #:	Start	Stop	Difference:	Meter	Meter	UOM:
----------	-------	------	-------------	-------	-------	------

Meter #:	Start	Stop	Difference:	Meter	Meter	UOM:
	Reading:	Reading:		Multiplier:	Total:	
0004958745	9948	10792	844.0	300	253200	KWH
0004958745	5959	6473	514.0	300	154200	KQH

Note: To convert kW readings to kWh divide by 2.
A value of zero may indicate that this measurement is not recorded under the rate plan.

* Billing adjustments, meter exchanges and rounding in calculations may cause a discrepancy in Total kWh, Total On-Peak and Total Off-Peak kWh figures displayed on this summary report.