

Reports

[Print](#)

Monthly Billing Summary Report

05/07/2013 - 06/05/2013

Dominion Virginia Power

Account Name(s): CITY OF ALEXANDRIA**Account Number:** 4452642962**Service Address:** 3600 WHEELER AVE
ALEXANDRIA, VA 22304**Rate Schedule:** Schedule 130**Start Date & Time:** 05/07/2013 00:00:00**Number of Days:** 30**Stop Date & Time:** 06/05/2013 12:29:59**Recorder ID:** 02123016

Determination of On and Off Peak Hours

Please refer to the on-peak and off-peak hours listed in your rate schedule

Total KWh: 251899**Total On-Peak kWh:** 118991**Total Off-Peak kWh:** 132908

Highest On-Peak kW Demands for the Billing Period

Date:	On-Peak kW:	Time:
05/22/2013	478.2	1500
05/29/2013	475.5	1530
05/30/2013	474.7	1130
05/30/2013	473.3	1200
05/22/2013	472.8	1400

Highest Off-Peak kW Demands for the Billing Period

Date:	Off-Peak kW:	Time:
06/01/2013	445.2	1830
06/01/2013	442.5	1700
06/01/2013	441.5	1800
06/01/2013	440.4	1930
06/01/2013	439.8	1730

PEAK KVAR (Lead)

KVAR:	kW:	KVA:	Date:	Interval:
-18.4	302.4	303.0	05/14/2013	0830
-15.0	306.2	306.5	05/13/2013	1030
-8.3	305.9	306.0	05/13/2013	0930
-6.5	306.7	306.8	05/14/2013	0800
-4.4	308.9	308.9	05/13/2013	1000

PEAK KVAR (Lag)

KVAR:	kW:	KVA:	Date:	Interval:
131.4	448.5	467.3	05/31/2013	1600
122.1	419.3	436.7	06/01/2013	1200
121.9	456.3	472.3	05/31/2013	1430
121.4	421.5	438.6	06/03/2013	1000
120.8	421.5	438.4	06/03/2013	0930

CHANNEL/METER VERIFICATION

Channel Information

Channel #:	Channel Pulses:	Pulse Multiplier:	Channel Total:	UOM:
01	1865919	0.135	251899	KWH
02	1209504	0.135	163283	KQH

Meter Information

Meter #:	Start	Stop	Difference:	Meter	Meter	UOM:
----------	-------	------	-------------	-------	-------	------

Meter #:	Start	Stop	Difference:	Meter	Meter	UOM:
	Reading:	Reading:		Multiplier:	Total:	
0004958745	13899	14739	840.0	300	252000	KWH
0004958745	8312	8856	544.0	300	163200	KQH

Note: To convert kW readings to kWh divide by 2.
A value of zero may indicate that this measurement is not recorded under the rate plan.

* Billing adjustments, meter exchanges and rounding in calculations may cause a discrepancy in Total kWh, Total On-Peak and Total Off-Peak kWh figures displayed on this summary report.