

Graph revision AD - ga_front: Keys: 600 x 600 x 350 mm overall - the node storage-sizing envelope, filled exactly (the duty section 4 prose seed line 800 x 80
Graph revision AD - ga_front: Nitric acid day-station: 25 L day tank at the back, PVDF pump envelope in the guarded floor zone
Graph revision AD - ga_front: 2 M HNO3 at no more than 40 C; storage per X-SAF-09 (14 d at 1.17 L/d = 16.4 L net
Graph revision AD - ga_front: PVC-U tank and piping, PVDF pumps and valves, FKM or PTFE gaskets; 304L excluded

Aqueous Solutions (owner) AQS-MFG-WS_NITRIC-GA_FRONT
WS_NITRIC fabrication drawing GA_FRONT (AQS-PLAN-006 M3; gra
Type: fabrication drawing (GA / nozzle orientation / part sheet) Rev 0378f7e3 Issued 2
Created: flow graph pipeline Approved: not approved (study)
Sheet 1 of 1 AQS-DWG-001