

Graph revision AD - ga_side: Day tank OD 400 x wall 10 (study fab page - hold, W12), base head lapping the tray, top head and vent riser within the box
Graph revision AD - ga_side: Working levels: 25 L nominal and 16.4 L net reported from the model at the X-SAF-09 basis; the 30 L own bund is the room-side c
Graph revision AD - ga_side: Instruments (level high-high trip, temperature 40 C trip, density alarm, bund sump pH

Aqueous Solutions (owner) AQS-MFG-WS_NITRIC-GA_SIDE
WS_NITRIC fabrication drawing GA_SIDE (AQS-PLAN-006 M3; grap
Type: fabrication drawing (GA / nozzle orientation / part sheet) Rev 697b339c Issued
Created: flow graph pipeline Approved: not approved (study)
Sheet 1 of 1 AQS-DWG-001