

Graph revision AD - ga_front: Keys: 1250 x 1000 x 2276 mm overall - the design envelope (specialty_sizing, X-SPEC lane), filled by the roof
Graph revision AD - ga_front: Pulse-jet baghouse: 20 antistatic-polyester bags D150 x 1200 (11.31 m2 cloth, A/C 1.114 drawn against the 1.2 m3/min/m2 basi
Graph revision AD - ga_front: Capture air 756 m3/h at the 0.5 m/s hood-face class over the three draws (A-M-458)
Graph revision AD - ga_front: CS housing painted, bonded, grounded; deflagration vent panel on the +X wall (duty

Aqueous Solutions (owner) AQS-MFG-BAGHOUSE-GA_FRONT
BAGHOUSE fabrication drawing GA_FRONT (AQS-PLAN-006 M3; grap
Type: fabrication drawing (GA / nozzle orientation / part sheet) Rev 95c0f09d Issued 2
Created: flow graph pipeline Approved: not approved (study)
Sheet 1 of 1 AQS-DWG-001