

Graph revision AD - ga_front: Keys: 400 x 400 x 3700 mm overall - the node envelope (ess_tf design, X-MFG-43b), filled by the vent riser
Graph revision AD - ga_front: Packed Br2-recovery wash column: PVC-U DN100 Sch 80 at 1.5 m/s on the 35.9 m3/h purge (D_req 92 mm)
Graph revision AD - ga_front: Bed 3000 mm of 25 mm PVC-U Pall rings = NTU 6 x HTU 0.5 m (duty-held figures); re
Graph revision AD - ga_front: Duty section 3 material: PVC-U shell/sump/packing, FKM gaskets, no metal wetted pa

Aqueous Solutions (owner) AQS-MFG-ZNBR2_BR2_REGEN-GA_FRONT
ZNBR2_BR2_REGEN fabrication drawing GA_FRONT (AQS-PLAN-006 M
Type: fabrication drawing (GA / nozzle orientation / part sheet) Rev abb903df Issued
Created: flow graph pipeline Approved: not approved (study)
Sheet 1 of 1 AQS-DWG-001